



Selo are not the designers responsible for any wall detail if shown, you should know that we are not aware of any fire test evidence for wall constructions which are not, standard as defined in EN1363-1:2020, nor is it our responsibility to establish if such evidence exists.

Tested detail in accordance with EN1634-1, requires standard supporting wall constructions with a minimum of 200mm either side and above door frame. Flexible wall construction requirement is a minimum of 300mm between apertures. Minimum upstand in flexible standard wall construction 100mm.

Outside of these minimum dimensions specific fire test evidence should be sought.

All requirements of the Fire resistance field of application report from Warringtonfire, for the Selo product/s included in this drawing must be ensured, or an alternative fire assessment for any deviation including non-standard wall details must be sought from a competent and designated body for producing fire resistance assessments.

FOR FURTHER TECHNICAL DETAIL AND INFORMATION PLEASE
CONTACT THE SALES TEAM AT sales@selo-uk.com

				Remove all burrs and sharp edges.		FINISH:	N/A	COLOUR:	N/A
				Please report errors and omissions		PROJECT:	ARRIVA FD30	TOLERANCES IN mm UNLESS OTHERWISE NOTED X ± 1 X.X ±0.5 ANGULAR ±0.5 DEG	
				MATERIAL:	N/A	INT DWG NO:	SEL-DRW-PRD-ARRI-0004		
					NAME	DATE	EXT DWG NO:		
				DRAWN:	GT	29/7/22	DESCRIPTION:	SINGLE RH DOOR FD30	
A	Initial issue	GT	29/7/22	CHECKED:			selo	19dB	
REV:	COMMENT:	REVISED BY:	DATE:	APPROVED:				DO NOT SCALE PRINT	
						SCALE:	NTS	SHEET: 1 OF 1	REV. A