

Name	<b>FumaCE</b>
Description	<b>Single Blade Control Damper</b>
Application	<b>Smoke damper to be used as part of a complete smoke extraction system using either a natural ventilation or mechanical ventilation vertical shaft, multi-compartment.</b>
Applicant	<b>Linear Building Innovations T/A SELO</b> <b>K2 Kents Hill Business Park, Timbold Drive, Milton Keynes, Buckinghamshire, MK7 6BZ</b>  Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2): <b>N/A</b>  System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: <b>System 1</b>  In case of the declaration of performance concerning a construction product covered by a harmonised standard: <b>Centrum Techniki Okrętowej S.A. 2434</b>  Performed Assessment and verification of constancy of performance under: <b>System 1</b>
Issue	<b>2024</b>
Certificate No.	<b>Pending</b>

Essential Characteristics	Performance Result	Harmonised Technical Specification
<b>Nominal activation conditions/sensitivity:</b> Closure/opening during test at correct time and in allowable time	Automatic Activation - Passed	EN 12101-8:2011
<b>Response delay /closure time:</b>	Automatic Activation - Passed	EN 12101-8:2011
<b>Operational reliability:</b>	10,000 Operations - Passed	EN 12101-8:2011
<b>Fire Resistance:</b>		
Integrity – E	150	EN 12101-8:2011
Insulation – I	122	
Smoke leakage – S	150	
Mechanical stability (Under E)	Pass	
Maintenance of cross section (under E)	Pass	
High operational temperature	NPD	
<b>Durability:</b>		
Of response delay	Pass	EN 12101-8:2011
Of operational reliability	Pass	

Where pursuant to Article 37 or 38 the Specific Technical Documentation has been used, the requirements with which the product complies:

**The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.  
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for and on behalf of the manufacturer by:



**Jeff Jones** Technical Director



**Simplifying bespoke and  
complex building methods™**

call 020 3880 0339  
email [sales@selo-uk.com](mailto:sales@selo-uk.com)  
[www.selo.global](http://www.selo.global)

K2 Kents Hill Business Park  
Timbold Drive Milton Keynes MK7 6BZ  
Linear Building Innovations Ltd trading as Selo